



ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

Sheet : 1 of 6

NAME AND ADDRESS OF CUSTOMER M/s. CLARIANT POWER SYSTEM LIMITED. CLARIANT HOUSE, 799/A, BHANDARKAR ROAD, PUNE - 411004.	REPORT NO. : RP-1516-015113 DATE : 23.07.2015	
	CUSTOMER REF. NO. ERDA/BARODA/AAS	DATE 22.06.2015
	DATE OF SAMPLE RECEIPT 22.06.2015	DATE OF TESTING 14.07.2015 to 16.07.2015
	SAMPLE DESCRIPTION DRY TYPE AIR CORE TUNNING REACTOR Manufactured by : CLARIANT POWER SYSTEM LIMITED Rating : 25.8 KVAR Rated voltage : 11000 Volts Rated current : 57.74 Amps Number of Phases : 1 Power Frequency : 50 Hz Tunning Frequency : 50 Hz Winding : Aluminium Core type : Air core Cooling : AN Class of insulation : F Type of Tunning : H-05 Guaranteed maximum temperature-rise limit above ambient : 90°C	
SAMPLE IDENTIFICATION ERDA sample code number : ERDA-00096904 Manufacturer serial number : CPSL-37 Year of manufacture : 2015 Enclosed drawing number : 1) Name plate drawing 2) P-15/CPSL/R/01 REV. 0 Sheet 1 of 1		
TEST DETAILS As per sheet 2 of 6.	TEST SPECIFICATION As per sheet 2 of 6.	
TEST RESULTS : As per sheets from 3 of 6 to 5 of 6.		
TEST WITNESSED BY : Mr. Vinod Dhongade [Sr. Manager, QC, M/s. Clariant Power System Limited.]		
ENCLOSURE : Photographs of test sample - As per sheet 6 of 6.		
REMARKS : 1) Reactor conforms to the guaranteed requirement as per above mentioned reference standard for above mentioned test nos. 6 & 8. 2) Criteria limit has not been specified for test nos. 1 to 5 & 7.		
 PREPARED BY	 CHECKED BY	 APPROVED BY (Kapil J. Sharma)
Note : 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director , E.R.D.A. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.		
Caution : ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TE 1743989



TRUE COPY

VANITA VISHNU SHINDE
NOTARY GOVT. OF INDIA
DISTRICT (MAHARASHTRA)

